



**PULL IN PIPE FOR JOINT PLOW WITH CTC
PULL IN EXTRA CWP 2" CONDUIT FOR
FUTURE CAMPGROUND EXPANSION**

56-000-18-03702
1664 330TH ST

- | | | | |
|---|-----|----|---------------------|
| 1 | New | 30 | 500 MCM 15KV JAC |
| | New | 1 | FAULT INDICATOR-URD |
| | New | 1 | UM33 D6U56-18F |
| | New | 1 | UM48-2 |
| | New | 1 | UM6-1 |
| | New | 5 | UM6-10-15 |
| | New | 3 | UM6-20-60D |
| | New | 6 | UM6-3 |

- | | | | |
|-----|-----|----|------------------|
| 1.1 | New | 30 | 500 MCM 15KV JAC |
| | New | 6 | UM6-28-2 |

- 1 ADD FAULT INDICATOR ON TAP CABLE
- 1.1 SPLICE IN 3Ø 600A DISCONNECT BOX

330th St

35' CL

56-000-19-03800
1615 330TH ST

56-000-19-03706
1771 330TH STREET

56-000-19-03709
1693 330TH ST

