



Address 3128  
Aardvark Rd

100520000

CR 230 (Barrel Rd)  
approx. 1700 ft east of this  
pole

Elmdale

66.67 AARDVARK RD 229

Install primary riser on this pole and  
bore under CR 229 (66' ROW)  
Install primary UG (7200 volts) in 2"  
pipe then onto private property.  
Remove existing primary overhead  
from same pole

Owner Address KEVIN & LYNELLE  
3128 AARDVARK RD  
BURTRUM MN 56008

ELMDALE TWP-School District 487  
ELY 797 FT OF SLY 545 FT OF NW1/4 OF NW1/4, SUBJ TO CO RD EASEMENT  
(Note: Not to be used on legal documents)

9.97 100521001