




Scale: 1" : 242'



GENERAL LOCATION ONLY.
DO NOT USE TO LOCATE FOR EXCAVATION
CALL 1-800-252-1166 FOR ONSITE LOCATIONS AND STAKING.



INSTALL A 32LB ANODE AT
50' W C/L HAVEN RD & 50'
SSBL 16597 HAVEN RD

INSTALL CP TEST POINT WITH A
32LB ANODE AT 60' W C/L HAVEN
RD & 90' N C/L RIVERWOOD DR

Work Order #: 110711007
Design Date: 12-06-2023

City: LITTLE FALLS
Quad/Sec/Twp/Rng: SW SEC-26 /T-41 /R-32

CP Section #: 41731
CP Area: AL1549-3

Designed By: P. TEESELINK
Designer Phone #: 612 910 1378