

SVC W/O # 55406716  
 \*\*MUST CONTACT EMERSON, HEAD OF  
 ARCHAEOLOGY, TO BE ON SITE FOR  
 INSTALLATION-HER NUMBER IS 612-725-2410\*\*  
 INSTALL 3" X 1 1/4" TR SVC TEE W/ 3/4" TAP  
 TAP 17" WCL LINDBERGH DR S (COUNTY RD 52)  
 INSTALL 185" OF 1 1/4" TR CL-2 SERVICE LINE  
 W/ 5/8" ANODELESS RISER W/SLEEVE  
 SVC EQUIP # 55348055

METERSET W/O # 55269707  
 METER MOVE IN # 55406926  
 INSTALL 250TC ERT'D OSM METERSET (CL-2)  
 @2PSI W/ 3/4" B42R REGULATOR W/ 1/4" X 5/16" ORIFICE  
 ON A 5/8" ANODELESS RISER W/SLEEVE  
 SET METER ON SOUTH WALL 28" E OF THE SW BLDG CORNER  
 METERSET EQUIP # 14213501

NOTE: BORE ALL PAVED STREETS AND DRIVEWAYS  
 Minimum depth requirements for pneumagopher crossings  
 of state highways and county roads is 60". Minimum  
 depth requirements for pneumagopher crossings of city  
 streets and township roads is 48". Minimum depth for  
 parallel installations on state highways and county  
 roads is 36". Minimum depth for parallel installations  
 on city streets and township roads is 30".



PROPRIETARY AND CONFIDENTIAL  
**55406716**  
 M16000 LITTLE FALLS  
 ONE CALL:  
 Morrison  
 \*NW30 T129R29  
 \* = this Page

LEGEND:

	ACTIVE		Interruptible
	DESIGNED		Existing
	PROPOSED		Normal
	ABANDONED		Futuro
	ABANDONED		Proposed

Address: 1620 LINDBERGH DR S  
 Customer: CHARLES LINDBERGH  
 HOUSE  
 Contact Person: PATRICIA  
 EMERSON  
 Contact Phone: 612-725-2410  
 Sales Rep: SHELLY HOUDE  
 Sales Rep Phone: 320-808-8630  
 Copies to Corrosion: No  
 Corrosion Approval: No  
 Permits: MORRISON COUNTY  
 Requested Install Date: 09/19/2010  
 Maps: 2-30

Approval: *Don McKibbin*  
 5-13-10

PROJECT DESCRIPTION:  
 CHARLES LINDBERGH HOUSE  
 DESIGNER: Jeff Pederson  
 PHONE #: 612-321-5065  
 DRAWN BY: Jeff Pederson  
 DESIGN DATE: 9/11/2010

Revised Print  
 Destroy All Others  
 Revision History  
 Date:  
 Description:  
 Design Approval:

IC Services  
 SCAN DATE: 11/11/2010  
 SHEET 1 OF 1

