

NOTE: BORE ALL PAVED STREETS AND DRIVEWAYS
 Minimum depth requirements for crossings of state highways and county roads is 60". Minimum depth requirements for crossings of city streets and township roads is 48".
 Minimum depth for parallel installations on state highways and county roads is 36". Minimum depth for parallel installations on city streets and township roads is 30".

NOT FOR CONSTRUCTION



MINNESOTA REGION

PROPRIETARY AND CONFIDENTIAL

PROJECT #: **59070961**

M16000 LITTLE FALLS

ONE CALL:
 Morrison
 *NE19 T129/R29
 * = this Page

INSTALL 2" TR CL-2
 6' - 7' OFF EDGE OF ROAD
 DIRECTIONAL BORE

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am a duly Licensed Registered Professional Engineer under the laws of the State of Minnesota.

Signature: _____
 Type or Printed Name: David Henningsgaard
 Date _____ REG. No. 22174

LEGEND:
 — ACTIVE MAIN
 — DESIGNED MAIN
 - - - PROPOSED ABANDONED MAIN
 ⊕ ABANDONED MAIN

PIPE REQUIRED:
 340' 2" TR CL-2

 340' PIPE

PROPOSED ABANDONED PIPE:

COPIES:
 PIPELINE INTEGRITY: N
 GAS VALVE: N
 DD NUMBER: N
 CORROSION: N
 EMP: N

FOLLOW INTERNAL PIPE SAMPLING REQUIREMENTS? N

SURVEYOR REQUIRED? N

PERMITS: MORRISON COUNTY NOTIFIED: LITTLE FALLS

PROJECT DESCRIPTION: NBCO MILL PARK TOWNHOMES

DESIGNER: Wendy Kronwall
 PHONE #: 612-321-5508
 DRAWN BY: Wendy Kronwall
 DESIGN DATE: 9/8/2011

REVISION INFO: 9-22-2011 WLK
 CHANGED MAIN LOCATION ~ UNABLE TO CAMERA SEWERS PREVIOUS RUNNING LINE

Main SCAN DATE: _____ SCALE 1" : 100' SHEET 1 OF 1

09/22/2011 01:10:24 PM DESIGNER EXPRESS DESIGN

