




Gopher State	Tailgate Session				Cty: <b>Morrison</b>	Type	Code	Quant	W/O#: <b>326625</b>	WP#:
#:	Switching Orders	Source Determined		Sec: <b>8</b>	New Const				LOC#: <b>89-000-09-00819</b>	
Time OK:	PPE Needed	Potential Hazards		Twp: <b>39N</b>	Sys Imp				Name: <b>SUBSTATION-BELLEVUE</b>	
Date OK:	Trees	Weather	Poles	Ins.	Rg: <b>31W</b>	Ret (RWR)			(H) Phone #:	
List:	Terrain	Public	Barracading		Signed By: <b>Swensen</b>		Date: <b>2/18/2015</b>		(W) Phone #:	
	Power Equip. Needed	Personal Tools			Staked By: <b>Luke Kasella</b>		Date: <b>5/26/2015</b>		(C) Phone #:	
	Sect./Fusing	Supervisor			Elec:		AFF #:		Acct#: <b>35015801</b>	
COMBINATION STAKING SHEET	Update:	Date:	Comments:		RFCd:		By:		Page: <b>1 of 2</b>	

Point	Pri. BSpan	Pri. Wire Size	Pole	OH Assy	Grnd.	Guy E	Lead	Anchor F	Trans G	Light M26-5	Ang.	J Box L Ped	Mod	El-bow	Cap	Spl-ice	Pri. Riser	Sec. Span	Sec. Wire	Sec. Unit	CWP Ped/ Loop	Misc Assy	Remarks
1	297	(4)4/0 ACSR																					CLASS 1 POLE *POLE #107061
			40-3	C2.51P	H1.1																		
			40-4	C2.21P	H5.2																		
1A			40-3		H1.1																	Y1.3	CLASS 1 POLE

Comments 1: <b>INSTALL 150 AMP REGULATORS ON BELLEVUE CIR. 1</b>	Start Ftg:	End Ftg:
Comments 2:	Start Ftg:	End Ftg:
Comments 3: <b>COUNTY PERMIT APPLIED FOR 5/26/15</b>	Start Ftg:	End Ftg:

Septic: <input type="checkbox"/>	Row 1:	Rd Permit <input type="checkbox"/>	Wire/Cables/Ser Size	WIRE FEET	# Wires	Ground FTG
Priv Elec: <input type="checkbox"/>	Row 2:	Cty Permit <input checked="" type="checkbox"/>				
LP Line: <input type="checkbox"/>	Line Ext\$ <b>0.00</b>	Bore/Push\$	Permit\$	Ped/Loop\$	Total\$ <b>0.00</b>	
Sprinkler: <input type="checkbox"/>	Socket on Site <input type="checkbox"/> Backfill Comments:					
Final Grade: <input type="checkbox"/>	Final Grade Comments:					
Brushing: <input type="checkbox"/>	Brushing Comments:					
Trees: <input type="checkbox"/>	Trees Comments:					
		State Permit <input type="checkbox"/>				
		DNR Permit <input type="checkbox"/>				
		Joint Trench <input type="checkbox"/>				
		Notify TWP <input type="checkbox"/>				
	Temp. Set:	By:	Comp.:		By:	



93RD ST

44'cl

1 1A

210TH AVE

- INSTALL 150 AMP REGULATORS
- SET POLE AT PT 1 7' DEEP
- SET POLE AT PT 1A 8' DEEP
- AND CUT TOP OFF IF NECESSARY
- FILL POLE HOLES WITH ROCK

Scale: 1" = 74 feet