



Install approx 60 ft 4/0
Underground from new
pole to new secondary
ped which is 75' east of
CL.

Install transformer pole with
anchor 45' west of CL New
transformer pole will be
approx. 30' south of existing
pole & anchor and at approx.
55'. Install 3 ph OH wire
(7200 v) from existing pole to
new pole with minimum of 22
ft clearance.