

Replace pole with taller one and install transformer on pole

North

Michael's Livestock Trucking

Minimum height of wire crossing CR & on north side of CR 19 = 22 ft.

Remove secondary wire over parking lot

