


COVERSHEET

	RUS Code:	W/O #:	427583
	EXT 740 C:	WP #:	
	Loan Nbr: BB8	LOC #:	89-000-06-01225
	Loan Ywr: 2017	Name:	GREGORY J KEDROWSKI
	AFF #:	(H) Phone #:	2329317
17330 MN-371 Brainerd, MN 56401 (218) - 829 - 2827	Elec:	(W) Phone #:	
	RFCd:	(C) Phone #:	
	By:	Acct #:	

City:	Staked By: LUKE M KASELLA
Sec: 6	Date: 10/9/2017 12:00:00AM
Twp: 39	Signed By: TERRY L THORKELSON
Rg: 32	09/22/2017

Tailgate Session	
Job Steps:	Work Procedures:
PPE Needed:	Job Hazards:
Source Control Verified/Size:	Equipment Needed:
Personal Tools:	1-Shot/K-Fuse Size:
Crew:	Date:
Comments:	

Gopher State	
Locate #:	Date OK:

Comments 2:
Comments 3:

Septic:	Row 1:	Rd Permit:	<input checked="" type="checkbox"/>
Priv Elec:	Row 2:	Cty Permit:	
LP Line:	Line Ext \$ 5,328.00 Bore/Push \$ 0.00 Permit \$ 50.00 Ped/Loop \$ 500.00 Total \$ 5878.00	Fees:	<input checked="" type="checkbox"/>
Sprinkler:	Backfill Comments:	TWP Permit:	
Final Grade:		State Permit:	
Brushing:		DNR Permit:	
Trees:		Joint Trench:	
Easements:		Notify TWP:	

Type of Device: Fuse	Size of Device: FUS-10T	Box/Switch #:
----------------------	-------------------------	---------------

Reel ID:	Start Ftg:	End Ftg:
Reel ID:	Start Ftg:	End Ftg:

CONDUCTOR SUMMARY			
STATUS	CONDUCTOR	TYPE	QTY (FT)
INSTALL	1/0 15KV JAC 220 MIL	PRIMARY	796
INSTALL	4 ACSR	PRIMARY	184
	UG-MODEL	SECONDARY	132
INSTALL	4/0 USE		10



- 1
- Ext 706 4 ACSR
- Ext 1 40-5
- Ext 1 A2.3
- Ext 1 E1.1
- Ext 1 E3-10
- Ext 1 F2.8
- Ext 1 G1.5 W9698
- Ext 1 H1.1
- Ext 1 K1.5
- New 1 A5.1

- 2
- 52' CL
- New 1 35-5
- New 184 4 ACSR
- New 1 A5.1
- New 1 E1.1
- New 1 E3-10
- New 1 F2.8
- New 1 H1.1
- New 1 UA1 12T FUSE

- 3
- New 796 15KV 1/0 SOLID (JACKET) 220 MIL
- New 1 UG7-15
- New 1 UM27-2
- New 1 UM6-1
- New 1 UM6-10-15

- 3A
- New 10 4/0 USE
- New 1 UM8-3-CWP

