

COVERSHEET

	RUS Code:	W/O #:	430269
	EXT 740 C:	WP #:	
	Loan Nbr: BB8	LOC #:	56-000-06-00304
	Loan Ywr: 2017	Name:	CHARLES E ANDERSON
	AFF #:	(H) Phone #:	5752331
17330 MN-371 Brainerd, MN 56401 (218) - 829 - 2827	Elec:	(W) Phone #:	
	RFCd:	(C) Phone #:	
	By:	Acct #:	35282901

City:	Staked By: LUKE M KASELLA
Sec: 6	Date: 10/31/2017 12:41:57PM
Twp: 132	Signed By: BRADLEY J CLARINE
Rg: 31	10/30/2017

Tailgate Session	
Job Steps:	Work Procedures:
PPE Needed:	Job Hazards:
Source Control Verified/Size:	Equipment Needed:
Personal Tools:	1-Shot/K-Fuse Size:
Crew:	Date:
Comments:	

Gopher State	
Locate #:	Date OK:

Comments 2:
Comments 3:

Septic:	Row 1:	Rd Permit: <input checked="" type="checkbox"/>
Priv Elec:	Row 2:	Cty Permit:
LP Line:	Line Ext \$ 0.00 Bore/Push \$ Permit \$ 0.00 Ped/Loop \$ 0.00 Total \$	Fees:
Sprinkler:	Backfill Comments:	TWP Permit:
Final Grade:		State Permit:
Brushing: <input checked="" type="checkbox"/>	HE NEEDS TO CLEAR ROUTE	DNR Permit:
Trees:		Joint Trench:
Easements:		Notify TWP:

Type of Device: Fuse	Size of Device: FUS-15T	Box/Switch #: N/A
----------------------	-------------------------	-------------------

Reel ID:	Start Ftg:	End Ftg:
Reel ID:	Start Ftg:	End Ftg:

CONDUCTOR SUMMARY			
STATUS	CONDUCTOR	TYPE	QTY (FT)
INSTALL	1/0 15KV JAC 220 MIL	PRIMARY	420
	UG-MODEL	SECONDARY	50
INSTALL	4/0 USE		20




56-000-06-00200
35402 AZTEC RD

Aztec Rd

#35401

1



2A

2

2A
New 1 UM8-3-CWP
New 20 4/0 USE

2
New 1 UM6-1
New 1 UM6-34
New 1 UM27-2
New 420 1/0 15KV JAC 220 MIL
New 1 UG7 15

1
31½' CL
Ext 1 A1.1
Ext 1 E1.1
Ext 1 H1.1
Ext 1 40-5
Ext 548 4 ACSR
Ext 1 A5.1
Ext 1 E3-10
Ext 1 F2.8
New 1 UA1 15T FUSE

